Monthly fire extinguisher check

Visual check to BS 5306-3. Tick or initial each box when the item passes; circle and note anything that fails.

BUILDING

EXTINGUISHER ID / LOCATION

TYPE AND SIZE

YEAR

Check	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
In its designated place, visible and unobstructed												
Pressure gauge in the green zone (where fitted)												
Safety pin and tamper seal intact												
No visible damage, corrosion, leaks or blocked hose or horn												
Operating instructions legible and facing outward												
Service label present, basic service within the last 12 months												

Basic service every 12 months by a competent person. Extended service every 5 years for water, foam, wet chemical and powder (sealed powder 10). CO2 and clean agent: overhaul every 10 years instead.

Free from inspectkeeper.com - or skip the paper: QR tags, checks from any phone, the log keeps itself.