

Monthly fire extinguisher inspection

Visual inspection per NFPA 10 / OSHA 1910.157(e)(2). Initial each box when the item passes; circle and note anything that fails.

BUILDING

EXTINGUISHER ID / LOCATION

TYPE AND SIZE

YEAR

Check	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
In its designated place												
Visible, nothing blocks access to it												
Operating instructions legible and facing outward												
Safety pin in place, tamper seal unbroken												
Full: hefted, or weighed if it has no gauge												
No damage, corrosion, leakage or clogged nozzle												
Pressure gauge in the green (operable) range												
Service tag present, annual maintenance not overdue												