

Monthly kitchen hood suppression system inspection

Owner inspection per NFPA 17A and the manufacturer's instructions. Initial each box when the item passes; circle and note anything that fails.

BUILDING

HOOD / COOKING LINE

SYSTEM MAKE AND MODEL

YEAR

Check	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
System in its place, cooking appliances not moved or swapped												
Manual pull station visible and unobstructed												
Tamper seals and indicators intact												
Service tag present and the last semiannual service within 6 months												
No physical damage, grease build-up or anything blocking nozzles and links												
Pressure gauge in the operable range (if the system has one)												
Nozzle blow-off caps in place and undamaged												
Class K extinguisher in place nearby												